

BY SPEED POST

No. J- 13012/51/2008-IA-II (T)
Government of India
Ministry of Environment & Forests

Paryavaran Bhawan
CGO Complex, Lodi Road
New Delhi-110003.

Dated: 7th Sept, 2009

To

✓ M/s KVK Nilanchal Power Pvt. Ltd.
6-3-1109 /A/1, 3rd Floor, Navbharth Chambers
Raj Bhawan Road, Somajiguda
Hyderabad-500 082.

Sub:- 3x350 Ph-I of 4x350 MW Coal based Thermal Power Project in Kandarej, Athagarh Tehsil, District Cuttack, Orissa by M/s KVK Nilanchal Power Pvt. Ltd.- Change in stack height- Relaxation in EC conditions regarding.

Sir,

The undersigned is directed to refer to your communication no. Nil dated 21st July, 2009 on the above mentioned subject.-

2. The request has been examined and in partial modification of this Ministry's letter of even no. dated 18.2.2009 for the above mentioned project, the following amendments/ additions are hereby made-

S.No.	Condition as stipulated	Condition as stipulated	Be read as
1	3(iii)	Two bi-flue stack of 275 m height each shall be provided with continuous online monitoring equipments for Sox, NOx, Particulate and Hg. Exit velocity of flue gases shall not be less than 22 m/sec.	Three stacks of 220 m having single flue each shall be provided with continuous online monitoring equipment for Sox, NOx particulate and exit velocity shall not be less than 22 m/sec.

3. Besides above the following additional conditions are stipulated for compliance-

Condition No. 3(xxix) - A copy of the clearance letter shall be sent by the proponent to concerned Panchayat, Zila Parishad/Municipal Corporation, Urban Local Body and the local NGO, is any, from whom suggestions/representations, if any, were received while processing the proposal. The clearance letter shall also be put on the website of the Company by the proponent.

(xxx)- The proponent shall upload the status of compliance of the stipulated EC conditions, including results of monitored data their website and shall update the same periodically. It shall simultaneously be sent to the Regional Office of MoEF, the respective Zonal Office of CPCB and the SPCB. The criteria pollutant levels namely, SPM, RSPM, SO₂ and NOX (ambient levels as well as stack emissions) or

critical sectoral parameters, indicated for the project shall be monitored and displayed at a convenient location near the main gate of the company in the public domain.

(xxx) The project proponent shall also submit six monthly reports on the status of compliance of the stipulated EC conditions including results of monitored data (both in hard copies as well by e-mail) to the respective Regional Office of MoEF, the respective Zonal Office of CPCB and the SPCB.

(xxxii) The environmental statement for each financial year ending 31st March in Form-V as is mandated to be submitted by the project proponent to the concerned State Pollution Control Board as prescribed under the Environment (Protection) Rules, 1986, as amended subsequently, shall also be put on the website of the company along with the status of compliance of EC conditions and shall also be sent to the respective Regional Offices of MoEF by e-mail.

4. All other conditions contained in this Ministry's letter of even number 18.2.2009, shall remain unchanged.

5. This issues with the approval of Competent Authority.

Yours faithfully,


(Lalit Kapur)
Director

Copy to:

1. The Secretary, Ministry of Power, Shram Shakti Bhawan, Rafi Marg, New Delhi-110001.
2. The Secretary, Environment and Forests Department, Government of Orissa, Bhubneshwar-751001.
3. The Chairman, Central Electricity Authority, Sewa Bhawan, R.K.Puram, New Delhi-110066.
4. The Chairman, Orissa State Pollution Control Board, A/118, Nilkantha Nagar, Unit-8, Bhubneshwar-751012 with request to display a copy of the clearance letter at the Regional Office, District Industries Centre and Collector's office for 30 days.
5. The Chairman, Central Pollution Control Board, Parivesh Bhawan, CBD-cum-office Complex, East Arjun Nagar, Delhi-110032.
6. The Chief Conservator of Forests, Eastern Regional Office, Ministry of Environment and Forests, A/3, Chandrasekharpur, Bhubneshwar-751023.
7. Director(EI), MoEF
8. Guard File
9. Monitoring File

(Lalit Kapur)
Director